



**Safety & Buildings Division**  
201 West Washington Avenue  
P.O. Box 2658  
Madison, WI 53701-2658

Evaluation #

200112-H

## Wisconsin Building Product Evaluation

### Heating System Reservoir:

**Manufacturer:** GK Products  
815 Plum Street  
Eau Claire, WI 54703

**Approved Product:** Trade Name: **Simply Heat**

**\*Water heater manufacturer, and model number designation,**  
see **LIMITATIONS OF APPROVAL** section.

**SCOPE OF EVALUATION:** The Heating System Reservoir manufactured by GK Products has been evaluated in accordance with the requirements of **Chapters Comm 63** and **64**, in accordance with the current Wisconsin Administrative Building And Heating, Ventilating And Air Conditioning Code.

The Heating System Reservoir manufactured by GK Products has been evaluated in accordance with the requirements of **Chapters Comm 22** and **23**, in accordance with the current Wisconsin Administrative Uniform Dwelling Code (UDC).

**NOTE: THIS EVALUATION IS FOR ONE (1) WATER HEATER AS PART OF THE SYSTEM. THE EVALUATION DOES NOT ADDRESS A BANK OF WATER HEATERS.**

"This evaluation is based on receipt of a signed statement from a Registered P.E. stating the system properly installed, passed the Wisconsin code required test(s) see test section. No other Department evaluation was conducted."

Applicant/Manufacturer: \_\_\_\_\_

Date: \_\_\_\_\_

\*ANSI Z21.47 (ANSI Z21.64): Access to the combustion chamber requires the use of tools.

\_\_\_\_\_ P.E.

Date: \_\_\_\_\_

**TESTS:** \*The water heater shall comply with ANSI Z21.10.3 or, see **LIMITATIONS OF APPROVAL** section.

**LIMITATIONS OF APPROVAL:** The **water heater** shall be installed in accordance with their listing and the manufacturer's recommendations.

**\*The water heater shall meet the definition of s. Comm 51.01 (29a) or installed in a rated enclosure as required by Comm ss. 50.19(1), 51.08(2), 64.20 and 64.21(2).**

**THE INSTALLED WATER HEATER/SYSTEM SHALL NOT BE USED AS A SOURCE OF POTABLE WATER.**

(UDC) requirements: ss. **Comm 22.11** through **22.13**, **22.15(2)(a)**, **22.19**, **22.22(3)**, **23.03**, **23.04**, **23.04(4)**, **23.065**, **23.10** & **23.18** shall be met.

All piping shall meet the requirements of **Comm 63.29(2)** and **Comm 64.23(1), (2), & (3)**.

This approval will be valid through December 31, 2006, unless manufacturing modifications are made to the product or a re-examination is deemed necessary by the department.

The Wisconsin Building Products Evaluation number must be provided when plans that include this product are submitted for review.

**DISCLAIMER:** The department is in no way endorsing or advertising this product. This approval addresses only the specified applications for the product and does not waive any code requirement not specified in this document.

Revision Date: August 10, 2001

Approval Date: May 25, 2001 By: \_\_\_\_\_

Lee E. Finley, Jr.  
Product & Material Review  
Integrated Services Bureau

200112-H.doc